



<b>Licence Number</b>	L5491/1984/18
<b>Licensee</b>	Woodside Energy Ltd
<b>ACN</b>	005 482 986
<b>Registered business address</b>	Woodside Plaza 240 St Georges Terrace PERTH WA 6000
<b>Date of amendment</b>	13 June 2016
<b>Prescribed Premises</b>	Category 10 Oil and gas production from wells Category 34 Oil or gas refining Category 52 Electric power generation Category 54 Sewage facility
<b>Premises</b>	Woodside Onshore Gas Treatment Plant De Witt Location 199, 197, Part lot 379 and 380 BURRUP PENINSULA WA 6714

## Amendment

The Department of Environment Regulation (DER) has amended the above licence in accordance with section 59 of the *Environmental Protection Act 1986* as set out in this Amendment Notice.

**Jonathan Bailes**

**Manager Licensing (Process Industries)**

*an officer delegated under section 20 of the Environmental Protection Act 1986 (WA)*

## Amendment Notice

This Notice is issued under section 59 of the *Environmental Protection Act 1986* (EP Act) to amend the licence issued under the EP Act for a prescribed premises as set out below. This notice of amendment is given under section 59B(9) of the EP Act.

## Amendment Description

This Amendment Notice is the result of a DER initiated amendment and relates to corrections to wastewater monitoring requirements specified in Table 2 of the licence.

## Decision

Table 2 of the licence specifies water quality monitoring parameters and frequency of analysis for wastewater discharges from the Jetty Outfall and Administration Drain. The previous version of the licence (L5491/1984/17) included the requirement to monitor for the parameter total oil. However, this parameter was removed in error from Table 2 when version 18 of the licence (L5491/1984/18) was granted by DER in September 2013. The error was identified by DER during a premises compliance inspection carried out in April 2016. This amendment is to reinstate the parameter total oil to Table 2.

## Amendment History

Instrument	Issued	Amendment
L5491/1984/18	13/06/2016	Amendment Notice 1  Licence amendment to reinstate the requirement to monitor for the parameter total oil in wastewater discharges.

## Amendments

- Table 2 of the licence is amended by the insertion of the red text shown in underline below:

**Table 1: Wastewater monitoring parameters and frequency of analysis**

Column 1	Column 2	Column 3	Column 4
Parameter	Unit	Frequency	
		Jetty Outfall	Administration Drain
<u>Total Oil</u>	<u>mg/L</u>	Per pump out	Per calendar month
Chemical Oxygen Demand	mg/L		
Conductivity	µS/cm		
Total Nitrogen	mg/L		
Total Phosphorus	mg/L		
Glycol	mg/L		
pH			
Sulphate	mg/L		
Sulphides	mg/L		
Anionic Surfactants	mg/L		
Total suspended solids	mg/L		
Turbidity	NTU		
aMDEA	mg/L		
Copper	µg/L		
Zinc	µg/L		
Cadmium	µg/L		
Lead	µg/L		
Mercury	µg/L		