



# Amendment Notice 1

<b>Licence Number</b>	L5997/1992/11
<b>Licence Holder</b>	Water Corporation
<b>ACN</b>	n/a
<b>Registered business address</b>	629 Newcastle Street LEEDERVILLE WA 6007
<b>Date of amendment</b>	8 March 2017
<b>Prescribed Premises</b>	Category 54: Sewage facility
<b>Premises</b>	Peelwood Parade HALLS HEAD WA 6210 Being Lot 10 on Diagram 79777

## Amendment

The Chief Executive Officer (CEO) of the Department of Environment Regulation (DER) has amended the above licence in accordance with section 59 of the *Environmental Protection Act 1986* as set out in this Amendment Notice.

Date signed: 8 March 2017

**Steve Checker**

**MANAGER LICENSING (WASTE INDUSTRIES)**

*an officer delegated under section 20 of the Environmental Protection Act 1986 (WA)*

## Amendment Notice

This notice is issued under section 59 of the *Environmental Protection Act* 1986 (EP Act) to amend the licence issued under the EP Act for a prescribed premises as set out below. This notice of amendment is given under section 59B(9) of the EP Act.

### Amendment Description

An amendment application (Application) was received by DER on 12 January 2017 from the Licence Holder requesting the removal of reference to groundwater monitoring bore B1/84 and replacing with B1/16, and an update to the Premises map which incorporates the updated monitoring bore locations on the licence L5997/1992/11 (Licence).

Under the Licence, monitoring of five groundwater bores is required on a quarterly basis.

The Licence Holder states in the Application that monitoring bore B1/84 was found to have a fracture casing in April 2016, preventing samples being taken. Subsequently, a new bore B1/16 was installed in November 2016 adjacent to B1/84 which has been decommissioned.

The Licence Holder has provided a bore completion log in support of the Application. GPS co-ordinates of B1/16 are:

- Latitude -32.53980577460727
- Longitude 115.69301174964355

The nature of the Application is administrative and does not pose an alteration or increase to any environmental risks at the Premises, hence there is no requirement for a risk assessment or update to the existing risk profile of the Premises.

### Decision

The Delegated Officer considers that the Licence Holder's Application can be granted, as set out in the Amendment section below.

### Amendment History

Instrument	Issued	Amendment
L5997/1992/11	11/02/2016	Licence amendment
L5997/1992/11	29/04/2016	Amendment Notice Extension of expiry date to 31 October 2032
L5997/1992/11	8/03/2017	Amendment Notice 1 Administrative amendment to replace bore B1/84 with B1/16

## Amendment

- Condition 3.4.1 of the licence is amended by the deletion of the text shown in strikethrough below and the insertion of the red text shown in underline below:

3.4.1 *The Licensee shall undertake the monitoring in Table 3.4.1 according to the specifications in that table and record and investigate results that do not meet any limit specified.*

<b>Table 3.4.1: Monitoring of ambient groundwater quality</b>					
<b>Monitoring point reference and location</b>	<b>Parameter</b>	<b>Target</b>	<b>Units</b>	<b>Averaging period</b>	<b>Frequency</b>
<del>B1/83, B1/84,</del> <u>1/16, B2/84,</u> <del>B6/88 and</del> <del>B7/88</del> <u>As depicted in</u> <u>the Premises</u> <u>Map in</u> <u>Schedule 1</u>	pH	None specified		Spot sample	Quarterly
	Electrical conductivity		mS/m		
	Total dissolved solids		mg/L		
	Total nitrogen				
	Total phosphorus				
Standing water level	mAHD				

Note: Note: In-field non NATA analysis of pH permitted

2. The Premises Map in Schedule 1 is removed and replaced with the following:

**Premises map**

The Premises is shown in the map below. The orange line depicts the Premises boundary.

