



## Annual Audit Compliance Report Form

*Environmental Protection Act 1986, Part V Division 3*

Once completed, please submit this form either via email to [info-der@dwer.wa.gov.au](mailto:info-der@dwer.wa.gov.au), or to the below postal address:

Department of Water and Environmental Regulation  
Locked Bag 10  
Joondalup DC WA 6919

### Section A – Licence Details

Licence number:	L6266/1991/10	Licence file number:	DER2014/000608
Licence holder:	Water Corporation		
Trading as:	Broome Wastewater Treatment Plant		
ABN:	28 003 434 917		
Registered address:	629 Newcastle Street, LEEDERVILLE, WA 6007		
Reporting period:	01 / 07 / 2020 to 30 / 06 / 2021		

### Section B – Statement of Compliance with Licence Conditions

Did you comply with all of your licence conditions during the reporting period?  
(please tick the appropriate box)

☐ Yes – please complete:

- section C;
- section D if required; and
- sign the declaration in Section F.

☒ No – please complete:

- section C;
- section D if required;
- section E; and
- sign the declaration at Section F.

### Section C – Statement of Actual Production

Provide the actual production quantity for this reporting period. Supporting documentation is to be attached.

Prescribed Premises Category	Actual Production Quantity
54	1,779 m3/day
61	Nil

### Section D – Statement of Actual Part 2 Waste Discharge Quantity

Provide the actual Part 2 waste discharge quantity for this reporting period. Supporting documentation is to be attached.


Prescribed Premises Category	Actual Part 2 Waste Discharge Quantity
Not Applicable	

Section E – Details of Non-Compliance with Licence Condition			
Please use a separate page for each condition with which the licence holder was non-compliant at a time during the reporting period.			
Condition no:	Condition 2 (Table 3)	Date(s) of non-compliance:	February and June 2021
Details of non-compliance:			
Average daily inflow into the Broome South WWTP exceeded the approved premises production capacity of 2,000 m <sup>3</sup> /day in February 2021 (2,110.45 m <sup>3</sup> /day) and June 2021 (2,019.42 m <sup>3</sup> /day).			
What was the actual (or suspected) environmental impact of the non-compliance?			
<b>NOTE</b> – please attach maps or diagrams to provide insight into the precise location of where the non-compliance took place.			
Nil environmental impact.			
Cause (or suspected cause) of non-compliance:			
Broome has the ability to turn pump stations around between the two wastewater treatment plants (Broome North and Broome South). These exceedances are the result of pump station turnaround delays.			
Action taken to mitigate any adverse effects of non-compliance and prevent recurrence of the non-compliance:			
Need to turn pump station around when daily inflow (averaged monthly) is approaching licence limit of 2000 m <sup>3</sup> /day discussed with operations.			
Was this non-compliance previously reported to DWER?			
<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
<input type="checkbox"/> Reported to DWER verbally		Date:    /    /	
<input type="checkbox"/> Reported to DWER in writing		Date:    /    /	



### Section F – Declaration

I/We declare that the information in this Annual Audit Compliance Report is true and correct and is not false or misleading in a material particular<sup>1</sup>. I/We consent to the Annual Audit Compliance Report being published on the Department of Environment Regulation's (DER) website.

Signature <sup>2</sup> :		Signature:	
Name: (printed)		Name: (printed)	
Position:		Position:	
Date:		Date:	
Seal (if signing under seal):			

<sup>1</sup> It is an offence under section 112 of the *Environmental Protection Act 1986* for a person to give information on this form that to their knowledge is false or misleading in a material particular.

<sup>2</sup> AACRs can only be signed by the licence holder or an authorised person with the legal authority to sign on behalf of the licence holder.