

Iron Ore 152-158 St Georges Terrace Perth 6000 Western Australia T+61 (8) 9327 2000

Private and confidential

Manager - Industry Regulation (Resources North) Department of Water and Environmental Regulation Regulatory Services - Environment Prime House, 8 Davidson Terrace **JOONDALUP WA 6027**

31 March 2022

Our reference

RTIO-HSE-0356323

Your reference

L6759

To whom it may concern

2021 Annual Audit Compliance Report for L6759 - Paraburdoo Wastewater Treatment Plant and **Liquid Waste Facility**

Attached is the 2021 Annual Audit Compliance Report (AACR) for Paraburdoo Wastewater Treatment Plant and Liquid Waste Facility as required by Condition 13 of L6759/1996/12.

This AACR covers the reporting period from 1 January to 31 December 2021, and addresses the requirements of the following licences:

- L6759/1996/12 version 1 (1 January to 19 May 2021)
- L6759/1996/12 version 2 (20 May to 31 December 2021).

Version 2 added treated wastewater irrigation, consolidated a previous licence amendment notice and updated the licence format.

Please contact	, Superintendent Environment, at	if you have
any queries.		



General Manager – Utilities, Iron Ore

Annual Audit Compliance Report form

Environmental Protection Act 1986, Part V

 \boxtimes

No

Section A – Licence Details				
Licence Number:	L6759/1996/12	Licence File Number:	DER2014/000866-1	
Licence Holder:	Pilbara Iron Company (Services) Pty Ltd			
Trading as:	Rio Tinto Iron Ore			
ACN:	107 210 248			
Registered address:	Level 18, Central Park. 152-158 St. Georges Terrace, PERTH WA 6000			
Reporting period:	1 January 2021 to 31 December 2021			
Section B – Statement of compliance with licence conditions				
Did you comply with all	of your licence conditions du	uring the reporting period?		
Ves Please complete Sections C. D. (if required) and sign the declaration in Section F.				

Section C	– Statement of actual product	ion
Provide the	actual production quantity for this report	ing period.*
Category	Premises description	Actual production quantity (2021)
54	Sewage facility	223 cubic metres per day
61	Liquid waste facility	3,839 tonnes

Please complete Sections C, D (if required), F and sign the declaration in Section E

Section D – Statement of actual Part 2 waste discharge quantity			
Provide the actual Part 2 waste discharge quantity for this reporting period.			
Category	Premises description	Actual Part 2 Waste Discharge Quantity (2021)	
Not Applicable – no categories relevant to Part 2 waste discharge quantity.			

Section E – Declaration			
I declare that the information in this Annual Audit Compliance Report is true and correct and is not false or misleading in a material particular ¹ . I consent to the Annual Audit Compliance Report being published on the Department of Water and			
	ation's (DWER) website.		
Signature ² :			
Name: (printed)			
Position:			
Date:	31 March 2022		

2021 AACR L6759 Page | 1

^{*}Supporting information provided in the relevant conditions of the 2021 Annual Environment Report

¹ It is an offence under section 112 of the *Environmental Protection Act 1986* for a person to give information on this form that to their knowledge is false or misleading in a material particular.

² AACRs can only be signed by the licence holder or an authorised person with the legal authority to sign on behalf of the licence holder.

Section F – Details of non-compliance with licence condition					
	se a separate ing period.	page for each con	dition with which the licence hold	der was non-compliant	at a time during
Conditio	n number:	9	Date(s) of non-compliance:	30 September 2021	
Details o	f non-complia	ince:			
The licence holder must monitor emissions in accordance with the requirements specified in Table 7. The amended licence of 20 May 2021 required an additional analyte, Oil and Grease, to be monitored quarterly. This analyte was not analysed in Q3, 2021.					
What was	s the actual (d	or suspected) en	vironmental impact of the non-	compliance?	
There was no environmental impact from the non-compliance. Samples taken in Q2 and Q4 returned results of <5mg/L (the limit of reporting).					
Cause (o	r suspected o	ause) of non-co	mpliance:		
Administrative error as additional analyte was not added to the standard quarterly monitoring suite until Q4.					
	Action taken to mitigate any adverse effects of non-compliance and prevent recurrence of the non-compliance:			the	
There were no adverse effects associated with the non-compliance requiring mitigation. In any case, the following action has been taken to prevent recurrence • Analyte has been added to the standard quarterly monitoring suite for Paraburdoo Waste Water Treatment Plant.					
Was this	non-complia	nce reported to t	he DWER?		
Yes:	Reported to [OWER verbally	Date:		⊠ No
	Reported to I	OWER in writing	Date:		

2021 AACR L6759 Page | 2