



Government of **Western Australia**
Department of **Environment Regulation**

Your ref: W5189/2012/1
Our ref: 2012/002943
Enquiries: Bhabesh Das
Phone: 93337521
Fax: 93337550
Email: bhabesh.das@der.wa.gov.au

Mr Rupert Duckworth
Water Corporation
PO Box 100
LEEDERVILLE WA 6902

Dear Mr Duckworth

ENVIRONMENTAL PROTECTION ACT 1986 – AMENDMENT TO WORKS APPROVAL

Works approval: W5189/2012/1
Premises: Kemerton Wastewater Treatment Plant
Lot 310 on Plan 31339 Marriott Road
WELLESLEY WA 6233

Further to my letter dated 21 May 2015, please find enclosed your amended *Environmental Protection Act 1986* works approval.

If you have any questions or objections relating to the works approval, please do not hesitate to contact the enquiries officer above on 93337521 for clarification or discussion of any grievances you have.

If you are concerned about, or object to any aspect of the amendment you may lodge an appeal with the Minister for the Environment within 21 days from the date on which this works approval is received. The Office of the Appeals Convenor can be contacted on 6467 5190 to find out the procedure and fee.

Members of the public may also appeal the amendments. The Appeals Registrar at the Office of the Appeals Convenor can be contacted after the closing date of appeals to check whether any appeals were received.

Yours sincerely,

Ed Schuller
Officer delegated under section 20
of the *Environmental Protection Act 1986*

4 June 2015

enc: Amended Works Approval



Works Approval

Environmental Protection Act 1986, Part V

Works Approval Holder: Water Corporation

Works Approval Number: W5189/2012/1

Registered office: 629 Newcastle Street
LEEDERVILLE WA 6007

Premises address: Kemerton Wastewater Treatment Plant
Marriott Road
WELLESLEY WA 6233
Being Lot 310 on Plan 31339 as depicted in Schedule 1.

Issue date: Thursday, 27 September 2012

Commencement date: Monday, 1 October 2012


Expiry date: Wednesday, 30 September 2016

The following category/s from the *Environmental Protection Regulations 1987* cause this Premises to be a prescribed premises for the purposes of the *Environmental Protection Act 1986*:

Category number	Category description	Category production or design capacity	Approved premises production or design capacity
54	Sewage facility: premises – (a) On which sewage is treated (excluding septic tanks); or (b) From which treatedsewage is discharged onto land or into waters	100 cubic metres or more per day	3600 cubic metres per day

Conditions

This Works Approval is subject to the conditions set out in the attached pages.


.....
Officer delegated under section 20
of the *Environmental Protection Act 1986*



Works Approval Conditions

1 General

1.1 Interpretation

1.1.1 In the Works Approval, definitions from the *Environmental Protection Act 1986* apply unless the contrary intention appears.

1.1.2 In the Works Approval, unless the contrary intention appears:

'Act' means the *Environmental Protection Act 1986*;

'CEO' means Chief Executive Officer of the Department of Environment Regulation;

'CEO' for the purpose of correspondence means;

Manager Licensing (Waste Industries)
Department of Environment Regulation
Locked Bag 33
CLOISTERS SQUARE WA 6850
Telephone: (08) 9333 7510
Facsimile: (08) 9333 7550
Email: industry.regulation@der.wa.gov.au;

'Commissioning' means the process of operation and testing that verifies the works and all relevant systems, plant, machinery and equipment have been installed and are performing in accordance with the design specification set out in the works approval application.



GENERAL CONDITIONS

GENERAL CONSTRUCTION AND OPERATIONAL DESCRIPTION

- 1 The works approval holder shall construct the works in accordance with the works approval application form dated 15 February 2012 and the documentation entitled "Kemerton Wastewater Treatment Plant Denitrification Upgrade", April 2012, Water Corporation.

Where the details and commitments of the documents listed in condition 1 above are inconsistent with any other condition of this Works Approval, the latter shall prevail.

SUBMISSION OF COMPLIANCE DOCUMENT

- 2 Subject to condition (1), the works approval holder shall submit a compliance document to the CEO following the construction of the works outlined in the works approval application and supporting documentation. The Compliance Document shall certify that the works were constructed in accordance with the conditions of Works Approval and documentation supporting the application to construct the works, and shall be signed by an authorised officer of Water Corporation, with the printed name and position of that person within the company, and preferably will contain the Company seal.

DENITRIFICATION SYSTEM COMMISSIONING

- 3 The works approval holder shall commission the Denitrification System for a period not exceeding three months.
- 4 The works approval holder shall notify the CEO in writing one week prior to the commencement of commissioning of the Denitrification System.
- 5 The works approval holder shall provide a Kemerton WWTP Denitrification System commissioning report to the CEO as part of the compliance document referred to in condition 2. The report shall contain data obtained during the commissioning of the Denitrification System confirming average nitrogen concentration of less than 2.5 mg/L have been achieved in the final discharge water.

Premises map

The Premises is shown in the map below. The pink line depicts the Premises boundary.

